### Cheri Dale - AQDX

Subject:

Rule 353 applicability to E-85 fuel

Location:

Palo Verde

\* Forward to DAVID Show

Start:

Thu 02/18/2010 8:30 AM

End:

Thu 02/18/2010 9:30 AM

\* Chezi -

Recurrence:

(none)

Rule 15 clear policy reiterates current rule

Meeting Status:

Meeting organizer

Organizer:

Cheri Dale - AQDX

Required Attendees:

Johanna Kuspert - AQDX; Jo Crumbaker - AQDX; Douglas Erwin - AQDX; Lucinda Swann -

AQDX; Kathy Houed - AQDX; Randy Ballard - AQDX

An inspector inquired if E-85 fuel dispensing facilities are covered under Rule 353. I reviewed the rule (see below) and have determined that E-85 would be covered under the current rule. On July 21, 2009, the Arizona Department of Weights and Measures submitted a letter to the EPA requesting a revision to the SIP to exclude E-85 from the definition

> E85 VR orcement Discretion

of gasoline. My concern is how this letter will or will not affect Maricopa County Air Quality.

February 12, 2010

Stage I E-85

South Coast Rule 461

Applicability: Rule 353, Section 204 and 503.

exempt from Stage II reportements ONLY

Topic: Inspection of E-85 fuel dispensing facilities.

Issue: How should the Air Quality Division inspect gasoline dispensing facilities that either dispense only E-85 fuel or dispense E-85 fuel along with other petroleum fuel products? Are E-85 fuel dispensing stations exempt from Maricopa County Air Quality Rule 353?

Discussion: 75 fuel ethanol plants in 20 states have been developed, with production capacities ranging from 500,000 to 310 million gallons per year (http://e85.whipnet.net/.) With the projected increase in the production capacity, the availability and use of E-85 will also increase in Maricopa County.

Per Maricopa County Air Quality Rule 353.204, GASOLINE is defined as any petroleum distillate or blend of petroleum distillate with other combustible liquid(s), such as alcohol, that is used as a fuel for internal combustion engines and has a vapor pressure between 4.0 and 14.7 psi (200 - 760 mm Hg.), as determined by the applicable method pursuant to subsections 503.2 and 504.2. Rule 353, Section 503 allows the Control Officer to accept a manufacturer's data sheet (MSDS), data certified by an officer of the supplying company, or test data for the product as verification of a vapor pressure. In a review of MSDS for E-85, the vapor pressure was as follows:

Speedway

SSA E85

43-776 mm Mg @ 100°F

Archer Daniels Midland Company

Fuel Ethanol E85

340-560

Aventine Renewable Energy

Fuel Ethanol E-85

340-560 @ 35°C

Two additional MSDS were reviewed but no vapor pressure was listed. The three MSDS listed above demonstrate that the E-85 fuel meets the vapor pressure requirement in the MCAQD definition of gasoline.

Rule 535, Section 503.2 discusses the two methods used for determining the vapor pressure of gasoline (reference Section 204). ASTM Method D323-94 includes procedures for the determination of vapor pressure of gasoline, volatile crude oil and other volatile petroleum products. The procedures are based on vapor pressures. For example, using an E-85 vapor pressure of 340 mm Hg, ASTM Method D323-94, Procedure A would be used to determine vapor pressure of the fuel. Method D4953 is the second method listed in Section 503.2 used to determine vapor pressure. Per the scope the "test method covers and is applicable to gasolines...with a vapor pressure range from 35-100kPa (5 to 15 psi)..." The vapor pressure is calculated to approximately 258 to 775 mm Hg. Again, this is within the vapor pressure range stated in the definition of gasoline.

Conclusion: E-85 is not specifically exempted from Rule 353 either in the definition of gasoline or in Section 305 exemptions. E-85 does meet Rule 353 definition of gasoline because of the following:

- E-85 is a "blend of petroleum distillate with other combustible liquid(s), such as alcohol..." as required in the definition of gasoline. E-85 is listed on MSDS as containing at least 80% ethyl alcohol, thus meeting the "...other combustible liquids..." section of the rule.
- The vapor pressure of E-85 listed on three MSDS is between 4.0 and 14.7 psi (200-760 mm Hg) range as required in the definition of gasoline.

Vapor pressure of E-85 can be determined using methods listed for determining vapor pressure:

- Compliance determination of the vapor pressure of E-85 can be determined by ASTM Method D323-94, Procedure C.
- Compliance determination of the vapor pressure of E-85 can be determined by ASTM Method D4953-93.

Therefore, E-85 is subject to the current Maricopa County Air Quality Regulation III, Rule 353 requirements.

Submitted February 12, 2010, by Cheri Dale, Maricopa County Air Quality Planner



GENE PALMA INTERIM DIRECTOR

# ARIZONA DEPARTMENT OF WEIGHTS AND MEASURES

4425 West Olive Avenue, Suite 134 Glendale, AZ 85302 602-771-4920 FAX 602-255-1950 800-277-6675 www.azdwm.gov

July 21, 2009

To: All Weights and Measures Stakeholders

Re: Stage II Enforcement Discretion for E85 Dispensers:

The Arizona Department of Environmental Quality, ("ADEQ"), and the Arizona Department of Weights and Measures, ("ADWM") will be asking the United States Environmental Protection Agency ("EPA") to take action on a revision to the State Implementation Plan, ("SIP") relating to Stage II Vapor Recovery in Area A.

This revision also includes a change in the definition of gasoline that would exclude E85, (a blend of 85% ethanol and 15% gasoline). If EPA acts upon this request, retailers would no longer be required to install Stage II vapor recovery controls on E85 dispensers.

This enforcement discretion letter will take effect as of the date of this letter. It will remain in effect until EPA takes action on the SIP revision for E85 dispensing facilities in area A, (the vapor control area).

This enforcement discretion is limited to Stage II requirements affecting E85 dispensers in area A. Additionally, please be advised that any discretion exercised is not necessarily representative of any action the EPA may initiate. If you have questions related to this enforcement discretion please contact Duane Yantorno at (602) 771-4933.

Sincerely

Gene Falma Interim Director

Arizona Department of Weights and Measures

Cc:

D. Ehrhart

D. Yantomo



# **Material Safety Data Sheet**

MSDS ID NO.: Revision date: 0137SPE012 01/30/2004

# 1. IDENTIFICATION OF THE SUBSTANCE/PREPARATION AND THE COMPANY/UNDERTAKING

Product name:

**SSA E85** 

Synonyms:

SSA ED75/ED85; E-75; E75; E-85; E85; Ethanol/Gasoline Fuel Blend; Fuel Ethanol

ED75/ED85

**Chemical Family:** 

Gasoline/Ethanol

Formula:

Mixture

Supplier:

Speedway/Superamerica LLC P O BOX 1500 ENON OH 45501

Other information:

419-421-3070

Emergency telephone number:

877-627-5463

## 2. COMPOSITION/INFORMATION ON INGREDIENTS

E85 is a mixture of ethyl alcohol and gasoline that is approved for use in an automobile spark ignition engine. Can contain small amounts of dye and other additives (>0.02%) which are not considered hazardous at the concentrations used.

#### **Product information**

Name	CAS Number	Weight %	ACGIH Exposure Limits:	OSHA - Vacated PELs - Time Weighted Ave	Other:
SSA E85	Mixture	100			

#### **Component Information**

MSDS ID NO.: 0137SPE012

Product name: SSA E85

Page 1 of 15

Comply with all applicable EPA, OSHA, NFPA and consistent state and local requirements. Use appropriate grounding and bonding practices. Store in properly closed containers that are appropriately labeled and in a cool well-ventilated area. Do not expose to heat, open flames, strong oxidizers or other sources of ignition. Do not cut, drill, grind or weld on empty containers since they may contain explosive residues. Avoid skin contact. Exercise good personal hygiene including removal of soiled clothing and prompt washing with soap and water.

For use as a motor fuel only. Product should never be used as a solvent due to its flammable and potentially toxic properties. Siphoning by mouth can result in lung aspiration which can be harmful or fatal.

Portable containers of 12 gallons (45 liters) or less should never be filled while they are in or on a motor vehicle or marine craft. Static electric discharge can ignite fuel vapors when filling non-grounded containers or vehicles on trailers. Containers should be placed on the ground. The nozzle spout must be kept in contact with the container before and during the entire filling operation. Use only approved containers. A buildup of static electricity can occur upon re-entry into a vehicle during fueling especially in cold or dry climate conditions. The charge is generated by the action of dissimilar fabrics (i.e., clothing and upholstery) rubbing across each other as a person enters/exits the vehicle. A flash fire can result from this discharge if sufficient flammable vapors are present. Therefore, do not get back in your vehicle while refueling. Cellular phones and other electronic devices may have the potential to emit electrical charges (sparks). Sparks in potentially explosive atmospheres (including fueling areas such as gas stations) could cause an explosion if sufficient flammable vapors are present. Therefore, turn off cellular phones and other electronic devices when working in potentially explosive atmospheres or keep devices inside your vehicle during refueling.

## 8. EXPOSURE CONTROLS / PERSONAL PROTECTION

#### PERSONAL PROTECTIVE EQUIPMENT

Engineering measures: Local or general exhaust required in an enclosed area or with inadequate ventilation.

Respiratory protection: Approved organic vapor chemical cartridge or supplied air respirators should be worn

for exposures to any components exceeding the TLV or STEL. Observe respirator protection factor criteria cited in ANSI Z88.2. Self-contained breathing apparatus

should be used for fire fighting.

Skin and body protection: Use nitrile rubber, viton or PVA gloves for repeated or prolonged skin exposure.

Eye protection: No special eye protection is normally required. Where splashing is possible, wear

safety glasses with side shields.

Hygiene measures: No special protective clothing is normally required. Select protective clothing

depending on industrial operations. Use mechanical ventilation equipment that is

explosion-proof.

#### 9. PHYSICAL AND CHEMICAL PROPERTIES:

Appearance:

Physical state (Solid/Liquid/Gas): Substance type (Pure/Mixture):

Color: Odor:

Molecular weight:

pH:

Boiling point/range: Melting point/range:

Decomposition temperature:

Specific gravity:

Density: Bulk density: Vapor density:

Vapor pressure: Evaporation rate: Clear Liquid

Liquid Mixture

Clear or Colored Hydrocarbon Not determined.

Not determi

90-437 F Not determined.

Not applicable. 0.70-0.77 5.9-6.3 lbs/gal No data available.

No data available. 43-776 mm Hg @ 100 F

No data available.

MSDS ID NO.: 0137SPE012 Product name: SSA E85

Page 6 of 15

# Appendix C: Material Safety Data Sheet for E85

#### Material Safety Data Sheet U.S. Department of Labor May be used to comply with Occupational Safety and Health Administration OSHA's Hazard Communication Standard, (Non-Mandatory Form) 29 CFR 1910.1200. Standard must be Form Approved consulted for specific requirements. OMB No. 1218-0072 IDENTITY (As Used on Label and List) Note: Blank spaces not permitted. If any item is not applicable, or no information is Fuel Ethanol E85 available, the space must be marked to indicate that. Section 1 Manufacturer's Name: Archer Daniels Midland Company Emergency Telephone Number: 800/424-9300 or 217/424-5200 Address: (Number, Street, City, State, and ZIP Code) Telephone Number for Information: 217/362-3980 4666 Fairles Parkway Date Prepared: 7/5/95 Decatur, Illinois 62526 Signature of Preparer (optional) Section II — Hazardous Ingredients/Identity Information Hazardous Components Other Limits (Specific Chemical Identity: Common Name(s)) **OSHA PEL ACGIH TLV** Recommended % (optional) Ethyl Alcohol (200 proof) CAS 0064-17-5 80% B0% Gasoline CAS 008-006-619 20% 20% Benzene CAS-0071-43-2\* 1ppm 10ppm < 1100ppm \*"A chemical known to the State of California to cause cancer" Section III — Physical/Chemical Characteristics Boiling Point: 96°-170°F Specific Gravity (H2O = 1): 0.76-0.78 Vapor Pressure (mm Hg.): 340-560 Melting Point: N/A Vapor Denisty (AIR - 1): 2.0-4.0 Evaporation Rate (Butyl Acetate = 1): Not Estimated Solubility in Water: 60-70 gm/100ml Appearance and Odor: Clear, colorless volatile liquid with ethereal odor. Section IV - Fire and Explosion Hazard Data Flash Point (Method Used): -20°F to -4°F TCC Flammable Limits: Not Estimated **LEL 1.4 UEL 19.0** Extinguishing Media: Carbon dioxide dry chemical, water for small fires. Polar solvent foam for large fires. Special Fire Fighting Procedures: Use necessary protective equipment and breathing apparatus as would normally be used when

fighting fires where there may be danger of breathing hazardous products of combustion.

OSHA 174, Sept. 1985

Unusual Fire and Explosion Hazards: Flammable liquid

(Reproduce locally)

# Appendix C: Material Safety Data Sheet for E85 - continued

Section V — Reactivity Data									
Stability	Unstable	Sta	ible X						
Conditions to Avoid: None in normal use									
Incompatibility (Materials to Avoid): May react vigorously with oxidizing materials.									
Hazardous Decomposition or Byproducts. Combustion may produce CO <sub>2</sub> , NO <sub>X</sub> and reactive hydrocarbons.									
Hazardous Polymerization	May Occur	Wi	Will Not Occur X						
Conditions to Avoid: None in normal us	e.								
Section VI — Health Hazard Data									
Devite (a) of Foton	Inhalation? Skir		Ingestion?						
Route(s) of Entry:	(A) (B)		(C)						
Health Hazards (Acute and Chronic):  (A) May cause mucous membrane irritation, unconsciousness, coma, respiratory failure and death.  (B) May cause skin irritation as a result of defatting.  (C) Moderately toxic (LD50 0.5 to 5 G/Kg), gastrointestinal irritation, vomiting, CNX depression, coma.									
Carcinogenicity:	NTP? JARC Mon-		phs	OSHA Regulated?					
car (mogenicity.	Not determined	Not determine	ed	Yes					
Signs and Symptoms of Exposure: May cause dizziness, loss of balance and coordination.									
Medical Conditions Generally Aggravate	ed by Exposure: Not determine	ned							
	wallowed, do not induce von piration if breathing has stop mediately with copious amou	ped. Call a physician.							
Section VII — Precautions for Safe I	landling and Use			F					
Steps to be Taken in Case Material is Released or Spilled: Eliminate all sources of ignition. Small spills should be flushed with large quantitles of water. Large spills should be collected for waste disposal.									
Waste Disposal Method: Do not allow to enter sewers where vapors may be ignited. Incinerate in furnace where permitted under appropriate federal, state & local regulations or dispose of in a site stipulated for hazardous materials.									
Precautions to Be Taken in Handling and	i Storage: Keep away from h Use with adequate		flames. Keep	container closed.					
Other Precautions: Use explosion proof	electrical equipment and nor	n-sparking tools. Grou	nd electrical e	equipment.					
Section VIII — Control Measures									
Respiratory Protection (Specify Type): A	r supplied mask for high con	centrations							
Ventilation	Local Exhaust: Preferred		Special: None						
ventilation	Mechanical (general): A	cceptable	Other: None						
Protective Gloves: Rubber									
Eye Protection: Goggles									
Outer Protective Clothing or Equipment:	Eye bath and safety shower								
Work/Hygienic Practices: N/A	*								
Page 2			*U.S.G.	P.O.: 1986-491-529/45775					